


Chimney Reinforcement Recommendations for Maxim M255



Three or Four Sections

When three or four sections of chimney are being used, a Chimney Snaplock Clamp (p/n 6500011) for each joint is recommended.

Five or More Sections

When five or more sections of chimney are being used, a Chimney Band Clamp Kit for each joint and a Chimney Attachment Ring (p/n 774) are recommended.

Fall Zone

If objects are placed in the fall zone of the chimney, a Chimney Guy-Wire Band Kit (p/n 776) or additional bracing is recommended.

NOTE

- Additional bracing may be necessary in certain areas such as those subject to severe weather, winds, freezing rain, etc.
- Inspect all bracing bi-annually for integrity.

